



PERIMETER ATTACHMENT

CORNER ATTACHMENT

PERIMETER ATTACHMENT

CORNER ATTACHMENT

NOTE:

1. WIDTH OF THE PERIMETER TREATMENT (A OR B) SHALL BE 10% OF THE BUILDING'S NARROWEST WIDTH (W) OR 40% OF THE BUILDING EAVE HEIGHT (H), WHICHEVER IS LESS WITH 4' BEING THE MINIMUM FOR WARRANTY REQUIREMENTS. SEE HALF SHEET REQUIREMENTS IN MECHANICALLY ATTACHED SECTION.
2. FOR ADHERED SYSTEMS, SEE INSULATION TABLE FOR ENHANCEMENTS.
3. FOR BALLAST SYSTEMS, REFER TO BALLAST SYSTEM APPLICATION TABLE.

ROOF AREA ZONE LAYOUT DETAIL

ACCEPTABLE WITH RE-FLEX TPO
MECHANICALLY ATTACHED SYSTEMS

PROJECT:

SCALE

NOT TO SCALE

Revision Date: 5-10-2015

#302

