



NOTE:

1. THE FOLLOWING APPLIES TO MECHANICALLY ATTACHED SYSTEM ONLY: FOR INSTALLATIONS REQUIRING INSULATION IN EXCESS OF 8", CONTACT RPI TECHNICAL SERVICES FOR ALTERNATE ATTACHEMENT REQUIREMENTS. A BARRIER BOARD MAY BE REQUIRED.
2. APPLY RE-FLEX CUT EDGE SEALANT TO ALL FIELD CUT REINFORCED MEMBRANE EDGES.

INSIDE CORNER PREFORMED FLASHING DETAIL

ACCEPTABLE WITH RE-FLEX TPO
MECHANICALLY ATTACHED SYSTEMS

PROJECT:

SCALE

NOT TO SCALE

Revision Date: 5-10-2015

#325

