



NOTE:

1. A FIELD WELDED SEAM MUST NOT BE WITHIN 9" OF THE CLAMPING RING OR EXTEND INTO THE DRAIN SUMP.
2. MEMBRANE MUST EXTEND A MINIMUM OF 1" BEYOND THE BOLT HOLES. BOLT HOLES IN MEMBRANE MUST BE CIRCULAR (ROUND HOLES) NOT STRAIGHT CUTS.
3. TAPERED INSULATION AT DRAIN MUST CREATE A ROOF SUMP (MINIMUM 36" X 36") WHERE APPLICABLE.
4. USE ONE TUBE OF WATER CUT-OFF MASTIC PER DRAIN.
5. ANY/ALL BALLAST MUST STOP AT DRAIN SUMP TAPER.

DRAIN WITH CLAMPING RING FLASHING DETAIL

ACCEPTABLE WITH RE-FLEX TPO
MECHANICALLY ATTACHED SYSTEMS

PROJECT:

SCALE

NOT TO SCALE

Revision Date: 5-10-2015

#335

